



HEALTHY PEOPLE. HEALTHY COMMUNITIES.

Alonzo L. Plough, Ph.D., MPH, *Director*

September 1, 2005

Ed Linardic  
LDG Architects  
1319 Dexter Ave. N, Suite 260  
Seattle, Washington 98109

RE: PLANS AND SPECIFICATIONS FOR:  
Tully's, 3100 Airport Way S., Seattle, Washington 98134  
SR# 1107070

DPD# 2404452

The plans and specifications for the above project have been reviewed and, in accordance with the provisions of the King County Board of Health, Rules and Regulations No. 05-06 are hereby **APPROVED** with the following conditions:

1. All refrigeration must be able to maintain food temperatures at 41° F or below.
2. Restroom must have self-closing doors.
3. The espresso and ice machines will be indirectly drained.
4. Painted surfaces in the food handling and dish wash areas will be painted with gloss or semi-gloss paint.

As required in The Food Code, upon completion of the construction and before you open for business, the owner shall:

1. Complete the enclosed application for the annual operations permit if you don't have a current permit and return with the correct fee. **Include a copy of this letter when applying for the annual operations permit.** If you open before you obtain your permit, the permit fee will double.
2. Obtain a pre-opening inspection approval. Contact Chris Skilton at 206-205-3429 to schedule a pre-opening inspection. Be sure all other inspections (plumbing, building, etc.) are done before you call the Health Department for an inspection.

Your establishment has been assigned the service request number **SR#1107070**. Please use this SR# in all future contact with us.

It is the responsibility of the food service establishment operator/owner to obtain all necessary permits and approvals. Operating the establishment without these required permits or approvals may subject you to legal action by the appropriate agencies. If you open without the Health pre-opening inspection, you may be closed. Failed pre-opening inspections will require a \$100.00 fee for a repeat inspection.

In the City of Seattle, pre-treatment facilities are required if wastewater contains more than 100 parts per million by weight of fat, oil, or grease of animal, vegetable, or mineral petroleum origin. Contact Gary Lockwood, Seattle Drainage and Wastewater Utilities, at 206-684-7750 for information.

Thank you for your compliance in this matter.

Sincerely,

*Patricia R. Ryan, R.S., M.S.P.H.*

Patricia R. Ryan, R.S., M.S.P.H.  
Plans Examiner  
Downtown Environmental Health

PRR  
Enclosure

Environmental Health Services

2124 - 4<sup>th</sup> Avenue, 4<sup>th</sup> Floor □ Seattle, WA 98121

T (206) 296-4632 F (206) 296-0188 □ [www.metrokc.gov/health](http://www.metrokc.gov/health)



City of Seattle  
Paul Schell, Mayor



King County  
Ron Sims, Executive

RCLLC 0000424